

TAZEWELL COUNTY HIGHWAY DEPARTMENT

DAN PARR
COUNTY ENGINEER

21308 ILLINOIS ROUTE 9
TREMONT, IL 61568

dparr@tazewell-il.gov

P: (309) 925-5532
F: (309) 925-5533

7/9/2026

ADDENDUM #1 FOR 23-08126-00-BR

This Addendum supplements and amends the original Drawings and Specifications and shall be taken into account in preparing proposals, and shall become a part of the Contract Documents. In case of conflict between the Drawings, Specifications and this Addendum, this Addendum will govern. Careful note of this Addendum shall be taken and all trades affected shall be fully advised for performance of the work.

This Addendum is necessary to address the Drilling and Setting Piles Pay Items.

- Plan Sheets Number 17 and 18 call for 7.0' min. of bentonite between the concrete at the bottom of the pile and the concrete encasement below the abutment. We were asked if any substitute materials would be acceptable in place of the bentonite. After discussing this with the Engineer of Record it was determined that we will allow a substitution of the bentonite to a dry, loose sand, as specified in 512.09(c) of the Standard Specifications.

Please contact our office if you have any questions.

Please sign and e-mail back a copy of acknowledgment of Addendum #1.

By signing below, I acknowledge receipt of Addendum #1 for 23-08126-00-BR

X _____, _____ **Representative**
(Name) (Company)

